

# Sells Intertie Annual Water Quality Report

(Includes: Big Fields & Kawulk Subdivision)

Public Water System #090400042

Calendar Year 2025

This report is a snapshot of your water quality. Included are details about where your water comes from, what it contains, and how it compares to standards set by regulatory agencies. We are committed to providing you with information because informed customers are our best allies.

## Do I need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. The Environmental Protection Agency (EPA) and Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

## Where does my water come from?

Your water comes from 3 ground water sources.

## Why are there contaminants in my drinking water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity including:

- microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife;
- inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming;
- pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses;
- organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems;
- radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

# WATER QUALITY TABLE

The table below lists all of the drinking water contaminants detected during the calendar year of this report. The presence of contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA or the State requires monitoring for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently.

Contaminants	MRDLG	MRDL	Your Water	Range		Sample Date	MRDL Exceeded	Typical Source
				Low	High			

## Disinfectants

Chlorine Units: Chlorine residual, ppm	4	4	0.5114	0.25	1.06	2025	No	Drinking water additive used for disinfection
---	---	---	--------	------	------	------	----	---

Contaminants	MCLG	MCL	Your Water	Range		Sample Date	Violation	Typical Source
				Low	High			

## Disinfection By-Products

Total Trihalomethanes (TTHMs) Units: ppb	N/A	80	16	ND	16	2025	No	By-product of drinking water chlorination
---	-----	----	----	----	----	------	----	---

Contaminants	MCLG	MCL	Your Water	Range		Sample Date	Violation	Typical Source
				Low	High			

### Inorganic Contaminants

Arsenic Units: ppb	0	10	9.7	8.6	11	2025	No	Erosion of natural deposits; runoff from orchards; glass and electronics production wastes
Barium Units: ppm	2	2	0.074	N/A	N/A	2021	No	Discharge of oil drilling wastes and from metal refineries; erosion of natural deposits
Chromium Units: ppb	100	100	2.9	N/A	N/A	2021	No	Discharge from steel and pulp mills and chrome plating; erosion of natural deposits
Fluoride Units: ppm	4	4	0.51	N/A	N/A	2021	No	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Nitrate [reported as Nitrogen] Units: ppm	10	10	2.5	N/A	N/A	2025	No	Runoff and leaching from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Sodium Units: ppm	N/A	N/A	59	N/A	N/A	2025	No	Erosion of natural deposits; salt water intrusion

Contaminants	MCLG	Action Level	Your Water	Range		Sample Date	A.L. Exceeded	Typical Source
				Low	High			

### Lead and Copper Rule

Copper Units: ppm - 90th Percentile	1.3	1.3	0.1	0.0092	0.15	2023	No	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
				0 sites over Action Level				
Lead Units: ppb - 90th Percentile	0	15	0.5	ND	3.1	2023	No	Corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits
				0 sites over Action Level				

Contaminants	MCLG	MCL	Your Water	Range		Sample Date	Violation	Typical Source
				Low	High			

**Radiological Contaminants**

Adjusted Alpha (Excl. Radon & U) Units: pCi/L	0	15	1.4	N/A	N/A	2025	No	Erosion of natural deposits
Uranium (combined) Units: ppb	0	30	5	N/A	N/A	2025	No	Erosion of natural deposits

**Special Statements**

**Educational Statement for Lead**

Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Sells Intertie Water System is responsible for providing high quality drinking water and removing lead pipes, but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family’s risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, contact your water utility.

Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <http://www.epa.gov/safewater/lead>.

**Additional Information for Arsenic**

While your drinking water meets the EPA standard for arsenic, it does contain low levels of arsenic. The EPA standard balances the current understanding of arsenic's possible health effects against the costs of removing arsenic from drinking water. The EPA continues to research the health effects of low levels of arsenic which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.

**Per- and Polyfluoroalkyl Substances (PFAS) Monitoring**

In April 2024, EPA announced a final National Primary Drinking Water Regulation (NPDWR) for six PFAS compounds. Under the rule, we are required to conduct initial monitoring by 2027 and comply with maximum contaminant levels (MCLs) by 2029. Last year, our water system evaluated for the presence of twenty-five PFAS compounds, including the six compounds involved in the new rule. No PFAS compounds were detected in your drinking water. PFAS are a group of thousands of synthetic chemicals that have been in use since the 1940s. PFAS have been found in a wide array of consumer and industrial products and as an ingredient in firefighting foam. Current scientific research has shown links between exposure to some PFAS chemicals and adverse health outcomes. Drinking water may be impacted in communities where these chemicals have contaminated the water supply. You can find more information about EPA’s actions to address PFAS in drinking water and links to informational resources here: [www.epa.gov/pfas](http://www.epa.gov/pfas)

**Additional Information for Unregulated Contaminant Monitoring Rule (UCMR)**

Our water system has sampled for a series of unregulated contaminants. Unregulated contaminants are those that don’t yet have a drinking water standard set by EPA. The purpose of monitoring for these contaminants is to help EPA decide whether the contaminants should have a standard. As our customers, you have a right to know that these data are available.

### **Service Line Inventory for Systems with Unknowns**

The Sells Intertie Water System was required to complete an inventory of service line materials to determine whether any service lines connected to the distribution system are made of lead material. We identified 103 service lines out of 1121 in the Sells Intertie Water System are made of unknown material. The service line inventory is available upon request, please contact us for more information.

---

## Microbiological Testing

We are required to test your water regularly for signs of microbial contamination. Positive test results could lead to follow-up investigations called assessments and potentially the issuance of public health advisories. Assessments could lead to required corrective actions. The information below summarizes the results of those tests.

Calendar Year	Sampling Requirements	Sampling Conducted (months)	Total E.coli Positive	Assessment Triggers	Assessments Conducted
2025	4 Samples due monthly	12 out of 12	0	1	1

During the year 2025, One Level 1 Assessment was required to be completed for our water system. One Level 1 Assessment completed.

### Definitions

A Level 1 Assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially harmful, waterborne pathogens may be present or that a potential pathway exists through which contamination may enter the drinking water distribution system. We found coliforms indicating the need to look for potential problems in water treatment or distribution. When this occurs, we are required to conduct assessment(s) to identify problems and to correct any problems that were found during these assessments.

## Significant Deficiencies

*Sanitary deficiencies are defects in a water system's infrastructure, design, operation, maintenance, or management that cause, or may cause interruptions to the "multiple barrier" protection system and adversely affect the system's ability to produce safe and reliable drinking water in adequate quantities.*

*The following is a listing of significant deficiencies that have yet to be corrected. Your public water system is still working to correct these deficiencies and interim milestones are shown, as applicable.*

---

### Deficiency Title: Storage Tank 3 (Hospital Tank) and Storage Tank 4 Rehabilitation

Date Identified: 7/19/2019 Overall Due Date: 12/31/2026

Deficiency Description: The interior of Storage Tank 3 (Hospital Tank) is in poor condition. The paint is either blistered or missing from the interior, and there is significant corrosion. The interior of Storage Tank 4 also shows significant corrosion.

Corrective Action Plan: It is recommended that both storage tanks be scheduled for inspection to determine if complete rehabilitation is warranted. During a complete tank rehabilitation, it would also be recommended that Storage Tank 3 have a new vent structure installed that meets present day design standards. Rehabilitation of Storage Tank 4 should include extending the overflow down to where it terminates between 12 and 24 inches above a splash pad and be screened with 24-mesh non-corrodible screen. Additionally, the tank ladders should be equipped with cages with locking hatches to discourage vandalism.

#### Milestone completed by 11/8/2019

*Corrective Action Notes: Inspection and repairs (not rehabilitation) will be addressed under IHS Water Storage Tank Inspection & Repair Project TU19-812. Project Summary sent. TOUA Project Contribution of \$265,000 provided to IHS 11/07/18. Additionally, IHS SDS Project AZ10067-2601 is priority #7 and proposes to replace this tank - SDS Narrative sent.*

#### Milestone completed by 7/27/2020

*Corrective Action Notes: Project delayed due to COVID 19 - extension requested*

#### Milestone completed by 9/21/2025

*Corrective Action Notes: Hospital tank physically disconnected from the water system. This SD now only applies to ST004*

---

**Deficiency Title: No Cross Connection Control Program**

Date Identified: 4/29/2025 Overall Due Date: 12/31/2026

Deficiency Description: The PWS does not have an active cross-connection control program. This is an ongoing deficiency identified in the previous sanitary survey. The program is needed to identify service connections that could potentially allow backflow of chemicals and contaminants into the distribution system, contaminating drinking water and affecting public health.

Corrective Action Plan: TOUA should establish a cross-connection program. High risk service connections should be identified and equipped with testable backflow prevention assemblies. Backflow prevention assemblies should be tested on an annual basis by a certified tester. Assemblies that fail the test must be repaired within the timeframe required by the plumbing code to ensure that the assemblies are in working condition and capable of preventing backflow.

## Definitions

<b>Term</b>	<b>Definition</b>
ppm	parts per million, or milligrams per liter (mg/L)
ppb	parts per billion, or microgram per liter (ug/L)
positive samples	the number of positive samples taken that year
% positive samples/month	% of samples taken monthly that were positive
pCi/L	picocuries per liter
ND	Not detected
N/A	Not applicable
MCLG	Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
MCL	Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
MRDL	Maximum Residual Disinfectant Level
MRDLG	Maximum Residual Disinfectant Level Goal
TT	Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.
AL	Action Level: The concentration of a contaminant which, if exceeded, trigger treatment or other requirements which a water system must follow.
90th Percentile	Statistical value used to determine if Action Level is exceeded. Determined by calculating the value at which 90% of the samples tested were below that value.

### How can I get involved?

Please feel free to contact the number provided below for more information or for a translated copy of the report if you need it in another language.

\*Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.\*

#### For more information please contact:

Ross Schroeder, Manager, P.O. Box 816, Sells, AZ 85634

**Phone:** (520) 383-5897

**Fax:** (520) 383-1838